

# Worldwide Pollution Control Association

WPCA-  
Southern Company  
Mercury Seminar  
October 30-31, 2012

All presentations posted on this website are copyrighted by the Worldwide Pollution Control Association (WPCA). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or to obtain copies for any other purposes than the training of attendees to WPCA Conferences is expressly prohibited, unless approved in writing by the WPCA or the original presenter. The WPCA does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of the WPCA.



Visit our website at [www.wpca.info](http://www.wpca.info)



# The Relationship Between Particulate & Mercury Control

---

Marisa LaPalomato

American Electric Power

October 30, 2012



# Background on AEP Testing

---

- Phase 1 Testing program started before proposed MATS rule was issued
  - Looked at stack levels of particulate matter, mercury and acid gases
  - Compared different Method 5 filters & temperatures (quartz vs. glass fiber, 250°F vs. 325°F)
- Phase 2 testing program started after issuance of final MATS rule. Focus on:
  - Stack levels of mercury and particulate matter
  - Mercury speciation across gas path, mercury removal rate across FGD and what drives it
  - Particulate removal across FGD and what affects it
  - Mercury re-emission



# Testing Summary

---

- Early Phase 2 testing program - look at whether higher PM levels into the FGD affected the FGD's PM removal efficiency
- Noticed a correlation between high PM levels into FGD and high(er) mercury at the stack
- Decided to evaluate this in addition to looking at different FGD operating conditions
- Most Phase 2 testing considered mercury & particulate matter at inlet/outlet of FGD
  - Varying loads
  - Varying FGD operation – L/G, oxidation air rate, pH
  - ESP detuning



# Unit “A” Characteristics

---

- 1320 MWg unit
- SCR - four layers of plate type catalyst
- 6 ESPs, 400 SCA
- Magnesium-enhanced lime FGD installed 1990s, designed for 95% SO<sub>2</sub> removal, 5 modules operate typically with 1 spare
- Typically burns Northern Appalachian High Sulfur (up to 7.5 lb SO<sub>2</sub>/mmBtu)



# Case Study A History

---

- Typically see higher than average mercury concentrations at the stack on this unit
- Typically see higher opacity than other similar units due to ESP design and condition
- ORP is tracked but is not typical with respect to mercury capture due to scrubber chemistry providing a reducing environment (producing sulfites)
- Testing program designed to look at PM and mercury removal across FGD under different operating conditions in the FGD and ESP and varying loads



# Case Study A

---

- Testing was conducted in March 2012
- ESP outlet ducts and stack tested simultaneously
  - Method 30B – total & speciated traps
  - Method 5 at ducts, 5B at stack
- Varied unit load (high/full, mid, low)
- FGD operating conditions
  - pH, L/G, varied independently and together
- Raised PM to FGD by “detuning” ESP

# Case Study A – PM Results

- Stack emissions rate was generally consistent regardless of PM loading to FGD and unit load
- There were two higher result outliers – one at mid and one at low load – further investigation needed to determine if these are related to FGD operation at the lower loads or if they are anomalies
- Varying FGD conditions had no affect on PM at the stack

	<b>Full Load Normal (lb/mmBtu)</b>	<b>Full Load - ESP Detuned (lb/mmBtu)</b>	<b>Low Load (lb/mmBtu)</b>
<b>FGD Inlet</b>	0.015	0.028	0.013
<b>Stack</b>	0.014	0.008	0.012



# Case Study A – Mercury Results

- Much higher elemental mercury at FGD Inlet under ESP detuned condition, but elemental mercury removal?!
- Overall mercury emissions rate was lower during this test than seen normally

		Full Load Normal (lb/TBtu)	Full Load - ESP Detuned (lb/TBtu)	Low Load (lb/TBtu)
FGD Inlet	Hg0	0.86	2.14	0.07
	Hg2+	7.19	6.29	8.11
	HgT	8.05	8.36	8.18

Stack	Hg0	0.56	0.81	0.09
	Hg2+	0.26	0.35	0.36
	HgT	0.81	1.16	0.45



## Unit “B” –Characteristics

---

- 840 MWg unit
- SCR - three layers of plate type catalyst
- 2 ESPs, <200 SCA
- Jet Bubbling Reactor (JBR) installed 2009, designed for 99.5% SO<sub>2</sub> removal
- Typically burns Northern Appalachian High Sulfur (up to 7.5 lb SO<sub>2</sub>/mmBtu)



# Case Study B History

---

- Unit B has very marginal ESPs and prior to installation of FGD operated with a gross load derate due to PM/opacity limits
- Testing program was originally designed to evaluate several things simultaneously
  - Cause of ID fan erosion and determination of optimal operating conditions to avoid it
  - Mercury & PM removal efficiencies across FGD



# Case Study B

---

- Testing was conducted in April 2012
- ESP A & B outlet ducts and stack tested simultaneously
  - Method 30B – total & speciated traps
  - Method 17 at ducts, 5B at stack
- Varied oxidation air rate to JBR
  - Took ORP (Oxidation Reduction Potential) readings during varied oxidation air test runs
  - ORP varied 150-300 mV but readings were inconsistent likely due to problems with the handheld probe

# Case Study B – PM Results

---

- ESP A & B outlet ducts see very different PM loading rates despite similar gas flows
- JBR achieved 80%+ PM removal under all loads/operating conditions tested

	<b>Full Load Average lb/mmBtu</b>	<b>Mid Load Average lb/mmBtu</b>	<b>Low Load Average lb/mmBtu</b>
<b>ESP A Outlet</b>	0.151	0.061	0.083
<b>ESP B Outlet</b>	0.088	0.02	0.074
<b>Stack</b>	0.0082	0.0049	0.0060

# Case Study B – Mercury Results

		Full Load Average lb/TBtu	Mid Load Average lb/TBtu	Low Load Average lb/TBtu
<b>ESP A Outlet</b>	<b>Hg2+</b>	10.74	11.29	12.58
	<b>Hg0</b>	1.03	0.49	0.21
	<b>HgT</b>	11.77	11.78	12.74
<b>ESP B Outlet</b>	<b>Hg2+</b>	14.38	11.86	8.63
	<b>Hg0</b>	0.72	0.4	0.45
	<b>HgT</b>	15.1	12.26	9.08
<b>Stack</b>	<b>Hg2+</b>	0.07	0.07	0.27
	<b>Hg0</b>	1.16	0.45	0.11
	<b>HgT</b>	1.23	0.51	0.38

# Case Study B – Mercury Results

		Full Load Average	Mid Load Average	Low Load Average
% Removal	Hg2+	99.4%	99.4%	97.5%
	Hg0	-32.6%	-1.1%	66.7%
	HgT	90.8%	95.8%	96.5%

- Mercury re-emission under full load operation
- Higher % of elemental mercury going into the FGD from ESP A
- Random sampling from other time periods shows even higher amount of elemental mercury being emitted
- Related to the high PM going into the FGD?



# Next Steps

---

- Plan for more testing of mercury at FGD inlet/outlet with ESP detuned
- The next unit to test will be equipped with a JBR and continuous mercury monitoring at FGD inlet/outlet
  - Unit is similar to Unit “B” in coal quality & FGD design
  - Testing was planned for early October but had to be deferred
- Possible re-test on Unit A, which currently has continuous mercury monitoring at FGD inlet and stack
- Plan to monitor ORP during testing



# Questions/discussion

---